
# FIRE DOOR ALARM RELEASE with BATTERY BACKUP

UL File No. S24769 • California State Fire Marshal Listed

The Lawrence AR-D2 is a failsafe time delayed fire door release device with battery backup. A constantly energized solenoid causes a fire door to close after a preset time delay upon an initiation signal from a fire alarm control panel or local detectors. An internal battery backup system prevents door closing due to a power loss for up to 7-days, as well as supporting local detectors and warning devices powered by it.



#### AR-D2 Alarm Release shown with "Easy-Reset" Chain Operated Fire Door

### Mounting

- · Standard wall mount for right-side pull
- Can be rotated 90° for bottom-pull, or 180° for left-side pull (with indicator lights/test button on top), or ceiling mount
- Must be installed with UL Listed fusible links
- For use in indoor locations Max.122° F [50° C] to Min. 23° F [-5° C] non-icing, <85% non-condensing humidity

 Supports up to 50 lbs. maximum pull (supporting structure and anchoring) must be adequate for total weight of release and max. pull – approx. 75 lbs.)

Approximate overall dimensions 11" W x 10" H x 6" D

### **Electrical Characteristics**

- Universal input voltage: 100~240VAC 60Hz or 50Hz, 24VAC/DC
- Standby/full load amps: 115VAC 0.4/0.7, 230VAC 0.3/0.5, 24VAC/DC 0.6/1.1 (Full load current only required for optional warning devices)
- Battery backup power: 12VDC 12AH (supports 2-wire smoke detectors and annunciators)
- Initiation signal: Form C dry contact, 24VAC/DC (Max. impedance 12.2 ohms)
- Wire: 18 gauge recommended

AR-D2 is a suitable replacement for most existing release devices – verify compatibility with input voltage, initiation signal, and any ancillary devices.




4525 Littlejohn Street • Baldwin Park, CA 91706 (626) 869-0837 • Toll Free (866) 939-3399 • Fax (626) 869-0841 www.lawrencedoors.com

 Listed by UL and California State Fire Marshal (CSFM) UL864 compliant without the need for an uninterruptible power

- supply • For use on new or existing manual or motor operated roll-up or sliding fire doors
- · Powered by either building current, fire alarm control panel or UL1481 power supply
- Initiated by either fire alarm control panel or local detectors
- Time delayed release (approx. 10 seconds) upon initiation
- 7-day battery support of release functions, and up to 4 smoke detectors and warning devices powered by it
- External test button and LED indicators for AC power, close limit, latching and arming status, and for battery charging and battery power status
- Simplified installation with "Set-Tie" system to secure release latch until power is connected

### **Optional Features**

- Audible, visible or voice warning devices (annunciators) activated upon initiation to warn of impending fire door closing
- · Closed position detection to prevent release of a fire door that is already closed (when connected to a compatible motor operator limit switch or external proximity switch)



2. Warning & closed position features function only when power is present.

## Accessories





Audible / Visible Warnings



AR-D2-3/15

© 2015 Lawrence Roll-Up Doors, Inc. Lawrence Roll-Up Doors, Inc. reserves the right to change specifications without notice. Refer to Standard Specifications sheets (available upon request) for complete product information.